

ClipperCreek CP-15 “Check Point” Tester Instructions

Part Number 0500-01-000

1. Verify that service line power is applied to the EVSE under test.
2. Verify the **black** Vehicle Charge Request button is in the OFF position.
3. Plug the EVSE SAE J1772™ Connector into the CP-15 inlet
4. Press the **black** Vehicle Charge Request button ON to request a charge.
5. The green light indicates that power is applied to the tester.
6. Press the **black** Vehicle Charge Request button OFF to turn off the charge.
7. The green light turns off when a charge is no longer requested.
8. When a charge is in progress, press the **red** Ground Fault button to test the unit with 20mA of current between Line 1 and Ground.

Figure 1: The CP-15 Tester

